



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞  
e-mail [wsdinfo@wsd.gov.hk](mailto:wsdinfo@wsd.gov.hk)

電話  
Telephone 2829 4355

圖文傳真  
Facsimile 2824 0578

檔號  
Reference (4) in WSD 3321/16 Pt.1 T/J(1268)

5 October 2016

### Approval of “DELABIE” Self Closing Taps

Your letters ref. HK794 and HKH794 dated 30 August 2016 and 9 September 2016 respectively refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

**Name of Manufacturer:** Delabie SCS

**Country of Origin:** France

**Brand:** Delabie

**Details of Fitting:** Range of self-closing combination tap assemblies (chromium plated brass) with spring loaded headwork controlling both the flow and temperature with a dome type operating member. The spout outlet incorporates a plastic flow straightener. The inlet hoses incorporate a single check valve cartridge (suitable for backflow prevention against Fluid Category 2) and a plastic strainer. The 794000 model is supplied with isolation

valves for each inlet with a 3/8” captive nut end connection. Maximum working pressure 5.0 bar. Maximum operating temperature 60°C.

**Model:** 794000 & 794100

**Size:** Stainless steel braided PEX lined flexible hoses assemblies with 3/8” captive nut end connections

**Marking:** Delabie on operating member

**WRAS Approval Number:** 1603022

**Installation Requirements:** R001, R006, R009

**Expiry Date:** 31 March 2021

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water supply plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water supply plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)  
for Water Authority

c.c.      WSD 3321/1/82 ] - without catalogue  
            ME/MC        ] - with soft copy only



**794000**



**794100**