

Certificate No: BC1430/0814
Sample No: BC1430



24th September 2014

Mr. Jason Williams
Delabie UK
7 Henderson House
Hithercroft Road
Wallingford
Oxfordshire
OX10 9DG

BuildCert Ltd

Unit 30, Fern Close,
Pen-y-Fan Industrial Estate,
Oakdale, Gwent NP11 3EH

Tel: +44 (0)1495 236260

Fax: +44 (0)1495 249234

E-mail: info@buildcert.com

Web: www.buildcert.com

Dear Mr. Williams

Samples of the fittings described below have been subjected to relevant tests and examinations contained in the "National Health Service Model engineering specifications D 08 Thermostatic mixing valves (Healthcare premises)", and after considering the test reports the Technical Assessment Panel of BuildCerts' Thermostatic Mixing Valve Scheme finds that the fittings so described. When correctly installed and commissioned satisfies the requirements of the NHS specification D 08.

BC1430/0814

Range of concealed, adjustable thermostatic mixing valves. Both inlets incorporate a single check valve cartridge. Maximum working pressure 10.0 bar.

Application Codes: HP-SE, HP-WE, LP-SE and LP-WE

Size: ½" Male BSP inlets

Product Designations: Premix Nano 732115: thermostatic control for mixed water distribution
Premix Nano 732116: thermostatic control for mixed water distribution

Markings: Red and Blue dots on inlets. End cap stamped Delabie. Non-detachable end cap etched Delabie Nano.

Factor: Delabie SCS

License Expiry Date: 14th August 2019
(Providing BuildCert annual requirements are met)



110

The valves are suitable for the following applications with the following supply conditions:

Code	Operating Pressure range	Application
HP-SE HP-WE LP-SE LP-WE	High pressure High pressure Low pressure Low pressure	Shower Economy - maximum temperature 41°C Washbasin Economy - maximum temperature 41°C Shower Economy - maximum temperature 41°C Washbasin Economy - maximum temperature 41°C
Note: Flow Pressure HP 0.5~5 bar LP 0.2~1 bar Supply Temperature Hot 55~65°C Cold ≤ 25°C Maximum Static Pressure 10bar		

The fittings described above are licensed for a period of 5 years from the date of the BuildCert Approved Certificate. You will be advised when your product is due for re-assessment. The extent of any testing required for the product will be at the discretion of the Schemes' Technical Assessment Panel.

The manufacturer and/or applicant must maintain their ISO 9001 approval or the agreed quality system. Any change to the status of the quality system is required to be notified to the Scheme. A Certificate of compliance for the quality system is required to be sent to BuildCert annually.

Manufacturers or applicants may only quote in their sales literature, terms used in this letter when indicating the decision of the Panel in respect to their fittings, namely that the Technical Assessment Panel of the Scheme finds that the use of fittings, when correctly installed, commissioned and maintained, will not contravene the requirements of the model specification and that a reference to the fitting(s) will be included within the approved valve list on the BuildCert website.

A condition of licensing is that no modification to the fittings described above shall be made without first notifying the Scheme and submitting details of the modification and, if so required, samples of the fitting or unit as so modified for consideration by the Technical Assessment Panel. Failure to comply with this condition will result in the withdrawal of the BuildCert license. Resubmission will only be allowed if permitted by the BuildCert Technical Assessment Panel Committee.

Your products are required to be replicas of the samples described above, one of which is retained by the Scheme for future reference. The right is reserved to carry out quality surveillance inspections of your production arrangements.

You are asked to verify the details of your product as set out in this letter are correct and advise us of any discrepancies.

Yours faithfully



Paul Taylor
BuildCert General Manager

THIS IS TO CERTIFY THAT

Delabie UK

has had the following products Certified by BuildCert Limited
to the requirements of


**National Health Service Model Engineering Specifications D 08
Thermostatic Mixing Valves (Healthcare Premises)**

Products covered by this certification include

Premix Nano 732115: thermostatic control for mixed water distribution

Premix Nano 732116: thermostatic control for mixed water distribution

Designation of uses: HP-SE, HP-WE, LP-SE and LP-WE



Signature



Date

This approval is subject to continuing conformity with BuildCert requirements. The absence of a listing on the BuildCert website (www.buildcert.com) indicates that the approval is no longer valid

Certificate: BC1430/0814
Type Test & QMS
Issue Date: 24th September 2014
Expiry Date: 14th August 2019



110